



ISOMETRIC VIEW

GENERAL NOTES:

1. EXPANSION JOINT MINIMUM REQUIREMENTS:
 - a. 3/8" EXPANSION JOINT MATERIAL SHALL BE PLACED AT LEAST EVERY 15' IN WIDTH WITHIN THE DRIVEWAY APPROACH AND SHALL LINE UP WITH SIDEWALK EXPANSION JOINTS IF APPLICABLE.
 - b. 3/8" EXPANSION JOINT MATERIAL IS REQUIRED BETWEEN DRIVEWAY SLAB AND THE SIDEWALK AND THE DRIVEWAY APPROACH.
 - c. EXPANSION JOINT MATERIAL SHALL BE SECURED IN PLACE PRIOR TO CONCRETE PLACEMENT AND SHALL COMPLETELY SEPARATE ADJACENT SLABS EXTENDING FROM THE SURFACE TO GRAVEL BASE. PLACEMENT OF EXPANSION JOINT MATERIAL SHALL NOT BE FLOATED OR PRESSED INTO WET CONCRETE AFTER CONCRETE HAS BEEN PLACED.
 - d. AN ALTERNATIVE TO SETTING EXPANSION JOINT MATERIAL PRIOR TO PLACING CONCRETE WOULD BE TO SAW CUT FULL DEPTH 1/2" WIDE AND FILL WITH APPROVED MASTIC PER WSDOT 9-04.2(2) POURED RUBBER JOINT SEALER.
2. CONTROL JOINTS SHALL BE PLACED AT THE DISCRETION OF THE CONTRACTOR. CRACK REPAIR WITHIN THE WARRANTY PERIOD IS THE RESPONSIBILITY OF THE CONTRACTOR. CONTROL JOINT MINIMUM REQUIREMENTS; CONTROL JOINTS SHALL:
 - a. BE NO FARTHER APART THAN 10'.
 - b. NOT EXCEED A RATIO OF 1 TO 1.25 LENGTH TO WIDTH.
 - c. BE A MINIMUM OF 1" DEEP (FOR TROWEL OR SAW CUT).
 - d. BE ADDED AT ALL GRADE BREAKS.
3. CEMENT CONCRETE SHALL BE CLASS 4,000 CONCRETE PER SECTION 6-02 OF THE WSDOT STANDARD SPECIFICATIONS.
4. ALL EXTERNAL EDGES SHALL BE TROWELED WITH A 3/8" TO 1/2" RADIUS.
5. A 4" (MIN) THICK CSTC LAYER SHALL BE PLACED UNDER DRIVE APPROACH.
6. FIRST 2' OF DRIVE APPROACH (AT CURB SIDE) SHALL BE THICKENED TO MATCH BOTTOM OF CURB.
7. WHEN AN ASPHALT APPROACH IS USED THE ASPHALT SHALL BE PLACED IN 0.30' LIFTS PER WSDOT 5-04.3(7)
8. LAST 2' OF SIDEWALK (HOUSE SIDE) WILL BE THICKENED 2 EXTRA INCHES WHEN OTHER HARD SURFACES ARE NOT PROPOSED ADJACENT TO THE APPROACH.
9. SUBGRADE AND CSTC UNDER APPROACH SHALL BE COMPAKTED TO 95%.



SECTION A-A

SECTION VIEW - TYPE A CURB
(SEE NOTE 18)

APPROVED BY:


 ROBERT B. BLEGEN, P.E.
PUBLIC WORKS DIRECTOR

COMMERCIAL
CONCRETE APPROACH
ADJACENT SIDEWALK
STANDARD PLAN NO.
R-114

PUBLICATION DATE: 09/2025
REVISION NO.: 03

DESIGN CRITERIA		
	RESIDENTIAL	COMMERCIAL
DISTANCE FROM CURB RETURN	15' MIN.	75' MIN.
THROAT WIDTH ***	16' MIN.* ** 30' MAX.**	30' MIN.** 40' MAX.**
SETBACK FROM SIDE PROPERTY LINE AT R.O.W.	5' MIN.	5' MIN.
SETBACK FROM SIDE PROPERTY LINE	2' MIN.	2' MIN.
* 24' MINIMUM WIDTH IF DRIVEWAY LENGTH IS OVER 75', SEE R-117		
** THE TOTAL APPROACH WIDTH SHALL NOT BE GREATER THAN 50% OF TOTAL LOT FRONTAGE WIDTH.		
*** CONSTRUCT EXPANSION JOINTS PARALLEL WITH APPROACH CENTERLINE AS REQUIRED AT 15' MAX. SPACING WHEN DRIVEWAY WIDTHS EXCEED 30'.		